



REAL SMART HOME

REAL SMART HOME GmbH

APPMODULE

Presence Tracker App Documentation

Version: 1.2.1

Type: Application

Article No.: BAB-043

Documentation version I
Actual state 09/19
Date: 17. September 2019

EN



REAL SMART HOME GmbH

Hörder Burgstraße
D-44263 Dortmund

Email: [info\[at\]realsmarthome.de](mailto:info@realsmarthome.de)

Tel.: +49 (0) 231-586974-00
Fax.: +49 (0) 231-586974-15
www.realsmarthome.de

TABLE OF CONTENTS

- 1 Introduction..... 4**
 - Important information on the operating instructions4
- 2 Presence Tracker – Functional overview 4**
- 3 The innovative, modular App-concept for the building automation..... 5**
 - 3.1 Information about the APPMODULE.....5
- 4 App installation / Update 6**
- 5 App Settings 7**
 - 5.1 Instance.....7
 - 5.1.1 Presence Tracker7
 - 5.1.2 Availability7
- 6 Attachment 9**

1 INTRODUCTION

Thank you for your trust, and the purchase of the **Presence Tracker**-app for the BAB **APP**MODULE. The app »Presence Tracker« allows you to effortlessly monitor up to 50 IP addresses or domain names and integrate the results with your KNX installation. This documentation will help you get started with the app and aims to improve your setup experience.

REAL SMART HOME GmbH

IMPORTANT INFORMATION ON THE OPERATING INSTRUCTIONS

We reserve the right continually improve the product. This entails the possibility that parts of this documentation might be out-of-date. You will find the latest information at:

www.bab-appmarket.de

2 PRESENCE TRACKER – FUNCTIONAL OVERVIEW

The app »Presence Tracker« allows you to effortlessly monitor up to 50 IP addresses or domain names and integrate the results with your KNX installation. You can, for instance, start a scene with an EIS1 telegram when a device with a specific IP logs in to your network. Additionally, you can define custom texts representing both connection states which will be sent as EIS15 telegrams accordingly.


Highlights:

- Monitor up to 50 IP addresses or domain names
- Defining your own text for status changes

3 THE INNOVATIVE, MODULAR APP-CONCEPT FOR THE BUILDING AUTOMATION

The innovative, modular app concept for building automation. The **APPMODULE** brings the innovative, modular app concept into building automation. You can mix and match any of the diverse applications that are available to integrate third-party solutions. With these apps from the dedicated **BAB APP MARKET**, the **APPMODULE** becomes a tailor-made integration unit for your building automation.

HOW IT WORKS



Manufacturer of the **APPMODULE** [BAB TECHNOLOGIE GmbH](#)

Distribution of all apps for the **APPMODULE** [BAB APP MARKET GmbH](#)

App developer [REAL SMART HOME GmbH](#)

3.1 INFORMATION ABOUT THE APPMODULE

Please refer to the separate product documentation of the **APPMODULE** for a detailed product description and setup instructions.

http://www.bab-tec.de/index.php/download_de.html

Product variants:

The **APPMODULE** is available in three variants:

- **APPMODULE** KNX/TP – for stand-alone use on KNX/TP Bus
- **APPMODULE** EnOcean – for stand-alone use in the EnOcean wireless network
- **APPMODULE** IP – for use in an IP-based KNX installation (KNXnet/IP) or as extension for an **EIBPORT**

4 APP INSTALLATION / UPDATE

Please proceed as follows to install an App.

1. Open the APPMODULE web page: Enter <IP Address of APPMODULE> into your browser's address bar and press Enter. The APPMODULE web interface will appear.
2. Log in with your user credentials. Please refer to the APPMODULE documentation for login details.
3. Click on the menu entry "App Manager"
4. You are now on the page where already installed Apps are listed. The list will be empty if no apps have been installed. Click "Install App" in order to install a new app.
5. Now click on "Select App"; a file selector window will appear. Choose the app »Presence Tracker« and click "OK". The Smart Home App "Presence Tracker" must first be downloaded from the BAB APP MARKET (www.bab-appmarket.de).
6. After the message "Installation successful" appears, click "OK". You are ready to configure the App.
7. To update an already installed app, click on the App icon in the "App Manager".
8. The detail view of the App appears. Click on "Update App" to select the app package and start the update. The update version must be downloaded from the BAB APP MARKET.

After the message "Installation successful" appears, click "OK". The app has been updated. Your instance configurations will remain unchanged.

Information

To configurate the App please use Google Chrome.

5 APP SETTINGS

The app »Presence Tracker« allows you to effortlessly monitor up to 50 IP addresses or domain names and integrate the results with your KNX installation. You can, for instance, start a scene with an EIS1 telegram when a device with a specific IP logs in to your network. Additionally, you can define custom texts representing both connection states which will be sent as EIS15 telegrams accordingly. You can only monitor devices which respond to ping (ICMP) requests.

5.1 INSTANCE

Information

The browser-session expires after a period of 60 minutes due to inactivity. Unsaved changes to the configuration will be lost.

As soon as the App is installed, you can create so called "Instance". An Instance is one of several objects of the same class.

In order to create an instance, click on the following symbol "Create Instance".

5.1.1 PRESENCE TRACKER

Instance Name:

Choose a name for this new instance.

Comment:

Insert a description what this instance does.

5.1.2 AVAILABILITY

Monitored devices:

Sends cyclic ping requests to check if the remote host is available.

The app pings the monitored devices approximately every 15 to 20 seconds. Ping times can slightly vary in high network traffic.

Remote host address

IP or domain name of the remote device

Ping Response Timeout (in seconds)

Time interval in seconds which determines the moment when a device that has been removed will be marked as offline. There will be a connection attempt every 10 to 15 seconds.

Indicator

Will send a telegram when the remote host availability changes.

A 1 if the remote host is available.

A 0 if it is not.

Indicator

Will send a telegram when the remote host availability changes.

Text when available

Text to send when the remote host became available.

If this field is left blank, "Available" will be sent to the indicator address as a default value.

Text when unavailable

Text to send when the remote host became unavailable.

If this field is left blank, "Unavailable" will be sent to the indicator address as a default value.

Monitored Group Addresses

Monitors the arrival of telegrams to a group address in order to check its activity.

Group Address (any data type)

Monitored group address (of any data type)

Activity Timeout (in minutes)

Time interval in minutes which determines the moment a group address will be marked as inactive.

Indicator

Will send a telegram when the group address activity changes.

A 1 when the group address is active.

A 0 if it is not.

Indicator

Will send a telegram when the group address activity changes.

Text when active

Text to send when the group address becomes active.

If this field is left blank, "Active" will be sent to the indicator address as a default value.

Text when inactive

Text to send when the group address becomes inactive.

If this field is left blank, "Inactive" will be sent to the indicator address as a default value.

6 ATTACHMENT

function	EIS type	DPT	typical function	typical values	data	identifier
PriorityPosition	EIS1	DPT 1*	Wind alarm	1=high and inhibit	1 Bit	1-bit
Switch	EIS1	DPT 1*	Light switching	0=Off; 1=On	1 Bit	1-bit
DimControl	EIS2	DPT 3*	Dimming	0=Off; 1=On xxx=relative dimming 0-255=absolute dimming	1Bit 4Bit 8Bit	3-bit controlled
Time	EIS3	DPT 10*	Time	Hhh:mm:ss	3 Byte	Time
Date	EIS4	DPT 11*	Date	dd:mm:yyyy	3 Byte	Date
Value	EIS5	DPT 9*	Value	[-671088.64 ... 670760.96]	1Byte	2-byte float value
DimValue	EIS6	DPT 5*	Percent	0-100%	1Byte	8-bit unsigned value
DriveBlade Value	EIS6	DPT 5*	Position value	0-100%; 0-255	1Byte	8-bit unsigned value
DriveShutter Value	EIS6	DPT 5*	Position value	0-100%; 0-255	1Byte	8-bit unsigned value
Position	EIS6	DPT 5*	Control value Heating	0-100%; 0-255	1Byte	8-bit unsigned value
DriveMove	EIS7	DPT 1*	Move shutter	0=up 1=down	1Bit	1-bit
DriveStep	EIS7	DPT 1*	Adjusting the slat blind	0=up; 1= down; 0 or 1 during movement=stop	1Bit	1-bit
PriorityControl	EIS8	DPT 2*	Priority	0,1 switch; 3=forced off; 4=forced on	2Bit	1-bit controlled
FloatValue	EIS9	DPT 14*	IEEE	Floating-point value	4 Byte	4-byte float value
Counter 16bit	EIS10	DPT 7*	Counter 16 bit	0 - 65.535	2Byte	2-byte unsigned value
Counter 16bit	EIS10	DPT 8*	Counter 16 bit with sign	-32.768 - 32.767	2Byte	2-byte signed value
Counter 32bit	EIS11	DPT 12*	Counter 32 bit	0 - 4.294.967.295	4Byte	4-byte unsigned value
Counter 32bit	EIS11	DPT 13*	Counter 32 bit with sign	0 - 4.294.967.295	4Byte	4-byte signed value
Access Control	EIS12	DPT 15*	Access control	Card number	4Byte	Entrance access
Char	EIS13	DPT 4*	ASCII characters	Character	1Byte	Character
Counter 8bit	EIS14	DPT 5*	Value	0 - 255	1Byte	8-bit unsigned value
Counter 8bit	EIS14	DPT 6*	Value with sign	-128 - 127	1Byte	8-bit signed value
String	EIS15	DPT 16*	String	max. 14 characters	14 Byte	Character string

EIB/KNX devices exchange fixed prescribed data formats with each other. These are defined in types. The old designations of the types are EIS (EIB Interworking Standard) The new designations are DPT (Data Point Type)